

SAFETY AND BUILDINGS DIVISION Plumbing Product Review P.O. Box 2658 Madison, Wisconsin 53701-2658

Jim Doyle, Governor Jack L. Fischer, A.I.A., Secretary

July 28, 2008

CREST PRECAST, INC. STEVE MADER 609 KISTLER DR LA CRESCENT MN 55947-1721

Re: Description: SEWAGE TANKS, CONCRETE

Manufacturer: CREST PRECAST, INC.

Product Name: SEPTIC/SEPTIC, SEPTIC/PUMP, SEPTIC/SIPHON, HOLDING OR GREASE

INTERCEPTOR/SEPTIC

Model Number(s): 1500/4500

(72.5" L.L., 21.74/65.22 GAL/IN., 84" MAX. DEPTH OF BURY, 3020 G.P.D. WHEN USED AS A SEPTIC/SEPTIC TANK OR 755 G.P.D. WHEN USED AS A SEPTIC/PUMP OR SEPTIC/SIPHON TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL

WASTEWATER)

Product File No: 20080438

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of AUGUST 2013.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Neenah Foundry gasketed access cover.
 - Bilco locking hinged access cover.
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
 - Four inch discharge opening in riser.
 - Dual inlets at end of tank with one access opening above both inlets.
 - Dual outlets at end of tank with one access opening above each outlet.
 - Side outlets for dose tanks.
 - Bottom and side pipe openings for siphon, pump and holding tanks.
 - Six, eight and ten-inch inlet and outlet openings.
 - Press Seal "Cast-A-Seal" and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc..
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the
 department's stamp of approval. The plans and specifications must be open to inspection by an authorized
 representative of the department.

SBD-10564-E (N.10/97) File Ref: 08043803.DOC

CREST PRECAST, INC.
Page 2
July 28, 2008
PRODUCT FILE NO. 20080438

- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall
 and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and
 in a manor that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent
 quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220
 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.

This approval supersedes the approval issued on 08/28/2003 under product file number 20030284.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030284.

Updated Tank Cross-section. Our records show that the tank cross section(s) on file area at least 10 years old. To update our records, please submit tank cross section(s) with associated dimensions, liquid limits, gallons/inch, bury depths, bedding specs., risers, covers, baffles, etc.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST Engineering Consultant--Plumbing Product Reviewer Commerce; Safety & Buildings Div. PO Box 2658 201 W Washington Ave. Madison WI 53703-2658

Phone: 608-266-0955; Fax: 608-283-7456 E-mail: Jean.MacCubbin@wisconsin.gov